





LAMPIRAN

Lampiran 1. *Layout Panel*




Lampiran 2. *Wiring Diagram Electric Muffle Furnace*




Lampiran 3. Program *Furnace* Pada PLC Siemens


Totally Integrated Automation Portal																																																						
<h3 style="margin: 0;">Program blocks</h3> <h4 style="margin: 0;">Main [OB1]</h4> <div style="background-color: #e0e0e0; padding: 2px; margin-bottom: 5px;">Main Properties</div> <div style="background-color: #e0e0e0; padding: 2px; margin-bottom: 5px;">General</div> <table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 5px;"> <tr> <td style="width: 20%;">Name</td> <td style="width: 20%;">Main</td> <td style="width: 20%;">Number</td> <td style="width: 20%;">1</td> <td style="width: 20%;">Type</td> <td style="width: 20%;">OB</td> </tr> <tr> <td>Language</td> <td>LAD</td> <td>Numbering</td> <td>Automatic</td> <td></td> <td></td> </tr> </table> <div style="background-color: #e0e0e0; padding: 2px; margin-bottom: 5px;">Information</div> <table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 5px;"> <tr> <td style="width: 25%;">Title</td> <td style="width: 25%;">"Main Program Sweep (Cycle)"</td> <td style="width: 25%;">Author</td> <td style="width: 25%;"> </td> <td style="width: 20%;">Comment</td> <td> </td> </tr> <tr> <td>Family</td> <td> </td> <td>Version</td> <td>0.1</td> <td>User-defined ID</td> <td> </td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 5px;"> <thead> <tr style="background-color: #e0e0e0;"> <th style="width: 30%;">Name</th> <th style="width: 20%;">Data type</th> <th style="width: 20%;">Default value</th> <th style="width: 30%;">Comment</th> </tr> </thead> <tbody> <tr> <td colspan="4">Input</td> </tr> <tr> <td>Initial_Call</td> <td>Bool</td> <td> </td> <td>Initial call of this OB</td> </tr> <tr> <td>Remanence</td> <td>Bool</td> <td> </td> <td>=True, if remanent data are available</td> </tr> <tr> <td colspan="4">Temp</td> </tr> <tr> <td>NORMX_TEMP_OUT</td> <td>Real</td> <td> </td> <td> </td> </tr> <tr> <td>Constant</td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table> <h4 style="margin: 0;">Network 1: START SISTEM</h4> <div style="border: 1px solid black; padding: 10px; margin: 10px 0;"> </div> <h4 style="margin: 0;">Network 2: ALARM</h4>			Name	Main	Number	1	Type	OB	Language	LAD	Numbering	Automatic			Title	"Main Program Sweep (Cycle)"	Author		Comment		Family		Version	0.1	User-defined ID		Name	Data type	Default value	Comment	Input				Initial_Call	Bool		Initial call of this OB	Remanence	Bool		=True, if remanent data are available	Temp				NORMX_TEMP_OUT	Real			Constant			
Name	Main	Number	1	Type	OB																																																	
Language	LAD	Numbering	Automatic																																																			
Title	"Main Program Sweep (Cycle)"	Author		Comment																																																		
Family		Version	0.1	User-defined ID																																																		
Name	Data type	Default value	Comment																																																			
Input																																																						
Initial_Call	Bool		Initial call of this OB																																																			
Remanence	Bool		=True, if remanent data are available																																																			
Temp																																																						
NORMX_TEMP_OUT	Real																																																					
Constant																																																						





Totally Integrated Automation Portal					
<h2 style="margin: 0;">Program blocks</h2> <h3 style="margin: 0;">PID [OB30]</h3>					
PID Properties					
General					
Name	PID	Number	30	Type	OB
Language	LAD	Numbering	Automatic		
Information					
Title	Author		Comment		
Family	Version		0.1	User-defined ID	
Inputs					
Name	Data type	Default value	Comment		
▼ Input					
Initial_Call	Bool		Initial call of this OB		
Event_Count	Int		Events discarded		
Temp					
Constant					
Network 1:					


Totally Integrated Automation Portal																																																						
<p>Program blocks</p> <p>Data [OB31]</p> <p>Data Properties</p> <p>General</p> <table border="1"> <tr> <td>Name</td> <td>Data</td> <td>Number</td> <td>31</td> <td>Type</td> <td>OB</td> </tr> <tr> <td>Language</td> <td>LAD</td> <td>Numbering</td> <td>Automatic</td> <td></td> <td></td> </tr> </table> <p>Information</p> <table border="1"> <tr> <td>Title</td> <td></td> <td>Author</td> <td></td> <td>Comment</td> <td></td> </tr> <tr> <td>Family</td> <td></td> <td>Version</td> <td>0.1</td> <td>User-defined ID</td> <td></td> </tr> </table> <table border="1"> <thead> <tr> <th>Name</th> <th>Data type</th> <th>Default value</th> <th>Comment</th> </tr> </thead> <tbody> <tr> <td>▼ Input</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Initial_Call</td> <td>Bool</td> <td></td> <td>Initial call of this OB</td> </tr> <tr> <td>Event_Count</td> <td>Int</td> <td></td> <td>Events discarded</td> </tr> <tr> <td>▼ Temp</td> <td></td> <td></td> <td></td> </tr> <tr> <td>NORMX_PID_OUT</td> <td>Real</td> <td></td> <td></td> </tr> <tr> <td>Constant</td> <td></td> <td></td> <td></td> </tr> </tbody> </table> <p>Network 1:</p>			Name	Data	Number	31	Type	OB	Language	LAD	Numbering	Automatic			Title		Author		Comment		Family		Version	0.1	User-defined ID		Name	Data type	Default value	Comment	▼ Input				Initial_Call	Bool		Initial call of this OB	Event_Count	Int		Events discarded	▼ Temp				NORMX_PID_OUT	Real			Constant			
Name	Data	Number	31	Type	OB																																																	
Language	LAD	Numbering	Automatic																																																			
Title		Author		Comment																																																		
Family		Version	0.1	User-defined ID																																																		
Name	Data type	Default value	Comment																																																			
▼ Input																																																						
Initial_Call	Bool		Initial call of this OB																																																			
Event_Count	Int		Events discarded																																																			
▼ Temp																																																						
NORMX_PID_OUT	Real																																																					
Constant																																																						












Totally Integrated Automation Portal		
Network 3: INTERVAL TIME DATA LOGGING (4.1 / 4.1)		
3.1 (Page4 - 6)		
		




Totally Integrated Automation Portal																																																							
<p>Program blocks</p> <p>TIMER [OB123]</p> <p>TIMER Properties</p> <table border="1"> <thead> <tr> <th colspan="4">General</th> </tr> </thead> <tbody> <tr> <td>Name</td> <td>TIMER</td> <td>Number</td> <td>123</td> </tr> <tr> <td>Language</td> <td>LAD</td> <td>Numbering</td> <td>Automatic</td> </tr> <tr> <td colspan="4">Information</td> </tr> <tr> <td>Title</td> <td>"Main Program Sweep (Cycle)"</td> <td>Author</td> <td></td> </tr> <tr> <td>Family</td> <td></td> <td>Version</td> <td>0.1</td> </tr> <tr> <td></td> <td></td> <td>User-defined ID</td> <td></td> </tr> </tbody> </table> <table border="1"> <thead> <tr> <th>Name</th> <th>Data type</th> <th>Default value</th> <th>Comment</th> </tr> </thead> <tbody> <tr> <td>▼ Input</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Initial_Call</td> <td>Bool</td> <td></td> <td>Initial call of this OB</td> </tr> <tr> <td>Remanence</td> <td>Bool</td> <td></td> <td>=True, if remanent data are available</td> </tr> <tr> <td>Temp</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Constant</td> <td></td> <td></td> <td></td> </tr> </tbody> </table> <p>Network 1:</p>				General				Name	TIMER	Number	123	Language	LAD	Numbering	Automatic	Information				Title	"Main Program Sweep (Cycle)"	Author		Family		Version	0.1			User-defined ID		Name	Data type	Default value	Comment	▼ Input				Initial_Call	Bool		Initial call of this OB	Remanence	Bool		=True, if remanent data are available	Temp				Constant			
General																																																							
Name	TIMER	Number	123																																																				
Language	LAD	Numbering	Automatic																																																				
Information																																																							
Title	"Main Program Sweep (Cycle)"	Author																																																					
Family		Version	0.1																																																				
		User-defined ID																																																					
Name	Data type	Default value	Comment																																																				
▼ Input																																																							
Initial_Call	Bool		Initial call of this OB																																																				
Remanence	Bool		=True, if remanent data are available																																																				
Temp																																																							
Constant																																																							





Totally Integrated Automation Portal																																																															
<p>Program blocks</p> <p>MANUAL [OB124]</p> <p>MANUAL Properties</p> <table border="1"> <thead> <tr> <th colspan="6">General</th> </tr> </thead> <tbody> <tr> <td>Name</td> <td>MANUAL</td> <td>Number</td> <td>124</td> <td>Type</td> <td>OB</td> </tr> <tr> <td>Language</td> <td>LAD</td> <td>Numbering</td> <td>Automatic</td> <td></td> <td></td> </tr> </tbody> </table> <table border="1"> <thead> <tr> <th colspan="6">Information</th> </tr> </thead> <tbody> <tr> <td>Title</td> <td>"Main Program Sweep (Cycle)"</td> <td>Author</td> <td></td> <td>Comment</td> <td></td> </tr> <tr> <td>Family</td> <td></td> <td>Version</td> <td>0.1</td> <td>User-defined ID</td> <td></td> </tr> </tbody> </table> <table border="1"> <thead> <tr> <th>Name</th> <th>Data type</th> <th>Default value</th> <th>Comment</th> </tr> </thead> <tbody> <tr> <td>▼ Input</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Initial_Call</td> <td>Bool</td> <td></td> <td>Initial call of this OB</td> </tr> <tr> <td>Remanence</td> <td>Bool</td> <td></td> <td>=True, if remanent data are available</td> </tr> <tr> <td>Temp</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Constant</td> <td></td> <td></td> <td></td> </tr> </tbody> </table> <p>Network 1:</p>				General						Name	MANUAL	Number	124	Type	OB	Language	LAD	Numbering	Automatic			Information						Title	"Main Program Sweep (Cycle)"	Author		Comment		Family		Version	0.1	User-defined ID		Name	Data type	Default value	Comment	▼ Input				Initial_Call	Bool		Initial call of this OB	Remanence	Bool		=True, if remanent data are available	Temp				Constant			
General																																																															
Name	MANUAL	Number	124	Type	OB																																																										
Language	LAD	Numbering	Automatic																																																												
Information																																																															
Title	"Main Program Sweep (Cycle)"	Author		Comment																																																											
Family		Version	0.1	User-defined ID																																																											
Name	Data type	Default value	Comment																																																												
▼ Input																																																															
Initial_Call	Bool		Initial call of this OB																																																												
Remanence	Bool		=True, if remanent data are available																																																												
Temp																																																															
Constant																																																															



Totally Integrated Automation Portal																																																																																																																			
<p>Program blocks</p> <p>DATA HMI CONTROL [DB2]</p> <p>DATA HMI CONTROL Properties</p> <p>General</p> <table border="1"> <tr> <td>Name</td> <td>DATA HMI CONTROL</td> <td>Number</td> <td>2</td> <td>Type</td> <td>DB</td> </tr> <tr> <td>Language</td> <td>DB</td> <td>Numbering</td> <td>Automatic</td> <td></td> <td></td> </tr> </table> <p>Information</p> <table border="1"> <tr> <td>Title</td> <td></td> <td>Author</td> <td></td> <td>Comment</td> <td></td> </tr> <tr> <td>Family</td> <td></td> <td>Version</td> <td>0.1</td> <td>User-defined ID</td> <td></td> </tr> </table>						Name	DATA HMI CONTROL	Number	2	Type	DB	Language	DB	Numbering	Automatic			Title		Author		Comment		Family		Version	0.1	User-defined ID																																																																																							
Name	DATA HMI CONTROL	Number	2	Type	DB																																																																																																														
Language	DB	Numbering	Automatic																																																																																																																
Title		Author		Comment																																																																																																															
Family		Version	0.1	User-defined ID																																																																																																															
<table border="1"> <thead> <tr> <th>Name</th> <th>Data type</th> <th>Offset</th> <th>Start value</th> <th>Retain</th> <th>Accessible from HMI/O PC UA/Web API</th> <th>Writable from engineering HMI</th> <th>Visible in HMI engineering</th> <th>Setpoint</th> <th>Supervision</th> <th>Comment</th> </tr> </thead> <tbody> <tr> <td colspan="11">▼ Static</td> </tr> <tr> <td>TEMP_SETPOINT</td> <td>Real</td> <td>0.0</td> <td>0.0</td> <td>False</td> <td>True</td> <td>True</td> <td>True</td> <td>False</td> <td></td> <td></td> </tr> <tr> <td>PID_Output</td> <td>Real</td> <td>4.0</td> <td>0.0</td> <td>False</td> <td>True</td> <td>True</td> <td>True</td> <td>False</td> <td></td> <td></td> </tr> <tr> <td>RESET</td> <td>Bool</td> <td>8.0</td> <td>false</td> <td>False</td> <td>True</td> <td>True</td> <td>True</td> <td>False</td> <td></td> <td></td> </tr> <tr> <td>DATA_SETPOINT</td> <td>Real</td> <td>10.0</td> <td>0.0</td> <td>False</td> <td>True</td> <td>True</td> <td>True</td> <td>False</td> <td></td> <td></td> </tr> <tr> <td>PID_Output_HMI</td> <td>Real</td> <td>14.0</td> <td>0.0</td> <td>False</td> <td>True</td> <td>True</td> <td>True</td> <td>False</td> <td></td> <td></td> </tr> <tr> <td>TIMER_SETPOINT</td> <td>Time</td> <td>18.0</td> <td>T#0ms</td> <td>False</td> <td>True</td> <td>True</td> <td>True</td> <td>False</td> <td></td> <td></td> </tr> <tr> <td>RESET TIMER</td> <td>Bool</td> <td>22.0</td> <td>false</td> <td>False</td> <td>True</td> <td>True</td> <td>True</td> <td>False</td> <td></td> <td></td> </tr> <tr> <td>SET TIMER</td> <td>Bool</td> <td>22.1</td> <td>false</td> <td>False</td> <td>True</td> <td>True</td> <td>True</td> <td>False</td> <td></td> <td></td> </tr> </tbody> </table>						Name	Data type	Offset	Start value	Retain	Accessible from HMI/O PC UA/Web API	Writable from engineering HMI	Visible in HMI engineering	Setpoint	Supervision	Comment	▼ Static											TEMP_SETPOINT	Real	0.0	0.0	False	True	True	True	False			PID_Output	Real	4.0	0.0	False	True	True	True	False			RESET	Bool	8.0	false	False	True	True	True	False			DATA_SETPOINT	Real	10.0	0.0	False	True	True	True	False			PID_Output_HMI	Real	14.0	0.0	False	True	True	True	False			TIMER_SETPOINT	Time	18.0	T#0ms	False	True	True	True	False			RESET TIMER	Bool	22.0	false	False	True	True	True	False			SET TIMER	Bool	22.1	false	False	True	True	True	False		
Name	Data type	Offset	Start value	Retain	Accessible from HMI/O PC UA/Web API	Writable from engineering HMI	Visible in HMI engineering	Setpoint	Supervision	Comment																																																																																																									
▼ Static																																																																																																																			
TEMP_SETPOINT	Real	0.0	0.0	False	True	True	True	False																																																																																																											
PID_Output	Real	4.0	0.0	False	True	True	True	False																																																																																																											
RESET	Bool	8.0	false	False	True	True	True	False																																																																																																											
DATA_SETPOINT	Real	10.0	0.0	False	True	True	True	False																																																																																																											
PID_Output_HMI	Real	14.0	0.0	False	True	True	True	False																																																																																																											
TIMER_SETPOINT	Time	18.0	T#0ms	False	True	True	True	False																																																																																																											
RESET TIMER	Bool	22.0	false	False	True	True	True	False																																																																																																											
SET TIMER	Bool	22.1	false	False	True	True	True	False																																																																																																											

Totally Integrated Automation Portal										
<p>Program blocks</p> <p>DATA LOGGER [DB4]</p>										
DATA LOGGER Properties										
General										
Name	DATA LOGGER	Number	4	Type	DB					
Language	DB	Numbering	Automatic							
Information										
Title		Author		Comment						
Family		Version	0.1	User-defined ID						
Name	Data type	Offset	Start value	Retain	Access-ible from HMI/O PC UA/Web API	Wri-ta-ble in HMI engi-neer-ing	Visi-ble in	Set-point	Su-per-vi-sion	Comment
▼ Static										
Record	UDInt	0.0	0	False	True	True	True	False		
Name	String	4.0	'Data'	False	True	True	True	False		
id	DWord	260.0	1	False	True	True	True	False		
header	String	264.0	'Temperatur,SV,PID'	False	True	True	True	False		
▼ Data	Struct	520.0		False	True	True	True	False		
Temperatur	Real	520.0	0.0	False	True	True	True	False		
Setpoint	Real	524.0	0.0	False	True	True	True	False		
Output PID	Real	528.0	0.0	False	True	True	True	False		
Done bit	Bool	532.0	false	False	True	True	True	False		
Bussy bit	Bool	532.1	false	False	True	True	True	False		
Error bit	Bool	532.2	false	False	True	True	True	False		
Status	Int	534.0	0	False	True	True	True	False		
1sec	Bool	536.0	false	False	True	True	True	False		
5sec	Bool	536.1	false	False	True	True	True	False		
10sec	Bool	536.2	false	False	True	True	True	False		
1min	Bool	536.3	false	False	True	True	True	False		
5min	Bool	536.4	false	False	True	True	True	False		

Totally Integrated Automation Portal										
Name	Data type	Offset	Start value	Retain	Access- sible from HMI/O PC UA/W eb API	Wri- ta- ble in HMI engi- neer- ing I/O PC UA/ Web API	Visi- ble in HMI engi- neer- ing	Set- point	Su- per- vi- sion	Comment
ON_REC_DATA- LOG	Int	538.0	0	False	True	True	True	False		
REQ_BITDATA	Bool	540.0	false	False	True	True	True	False		

Totally Integrated Automation Portal										
<p>Program blocks</p> <p>Time of day DB [DB13]</p>										
Time of day DB Properties										
General										
Name	Time of day DB	Number	13	Type	DB					
Language	DB	Numbering	Automatic							
Information										
Title		Author		Comment						
Family		Version	0.1	User-defined ID						
Name	Data type	Offset	Start value	Retain	Access-ible from HMI/O PC UA/Web API	Wri-ta-ble in HMI engi-neer-ing	Visi-ble in HMI engi-neer-ing	Set-point	Su-per-vi-sion	Comment
▼ Static										
Seconds	Bool	0.0	false	False	True	True	True	False		
Minutes	Bool	0.1	false	False	True	True	True	False		
Hours	Bool	0.2	false	False	True	True	True	False		
Days	Bool	0.3	false	False	True	True	True	False		
HMI_Sec	Int	2.0	0	False	True	True	True	False		
HMI_Min	Int	4.0	0	False	True	True	True	False		
HMI_Hour	Int	6.0	0	False	True	True	True	False		

Totally Integrated Automation Portal																																																																																													
<p>Program blocks</p> <p>MANUAL_LOG [DB17]</p> <p>MANUAL_LOG Properties</p> <p>General</p> <table border="1"> <tr> <td>Name</td> <td>MANUAL_LOG</td> <td>Number</td> <td>17</td> <td>Type</td> <td>DB</td> </tr> <tr> <td>Language</td> <td>DB</td> <td>Numbering</td> <td>Automatic</td> <td></td> <td></td> </tr> </table> <p>Information</p> <table border="1"> <tr> <td>Title</td> <td></td> <td>Author</td> <td></td> <td>Comment</td> <td></td> </tr> <tr> <td>Family</td> <td></td> <td>Version</td> <td>0.1</td> <td>User-defined ID</td> <td></td> </tr> </table>						Name	MANUAL_LOG	Number	17	Type	DB	Language	DB	Numbering	Automatic			Title		Author		Comment		Family		Version	0.1	User-defined ID																																																																	
Name	MANUAL_LOG	Number	17	Type	DB																																																																																								
Language	DB	Numbering	Automatic																																																																																										
Title		Author		Comment																																																																																									
Family		Version	0.1	User-defined ID																																																																																									
<table border="1"> <thead> <tr> <th>Name</th> <th>Data type</th> <th>Offset</th> <th>Start value</th> <th>Retain</th> <th>Access-ible from HMI/O PC UA/Web API</th> <th>Wri-ta-ble in engi-neer-ing</th> <th>Visi-ble in HMI</th> <th>Set-point</th> <th>Su-per-vi-sion</th> <th>Comment</th> </tr> </thead> <tbody> <tr> <td colspan="11">▼ Static</td> </tr> <tr> <td>Record</td> <td>DInt</td> <td>0.0</td> <td>0</td> <td>False</td> <td>True</td> <td>True</td> <td>True</td> <td>False</td> <td></td> <td></td> </tr> <tr> <td>Name</td> <td>String</td> <td>4.0</td> <td>'MANUAL'</td> <td>False</td> <td>True</td> <td>True</td> <td>True</td> <td>False</td> <td></td> <td></td> </tr> <tr> <td>id</td> <td>DWord</td> <td>260.0</td> <td>1</td> <td>False</td> <td>True</td> <td>True</td> <td>True</td> <td>False</td> <td></td> <td></td> </tr> <tr> <td>header</td> <td>String</td> <td>264.0</td> <td>'Temperatur'</td> <td>False</td> <td>True</td> <td>True</td> <td>True</td> <td>False</td> <td></td> <td></td> </tr> <tr> <td colspan="11">▼ Data</td> </tr> <tr> <td>Temperatur</td> <td>Real</td> <td>520.0</td> <td>0.0</td> <td>False</td> <td>True</td> <td>True</td> <td>True</td> <td>False</td> <td></td> <td></td> </tr> </tbody> </table>						Name	Data type	Offset	Start value	Retain	Access-ible from HMI/O PC UA/Web API	Wri-ta-ble in engi-neer-ing	Visi-ble in HMI	Set-point	Su-per-vi-sion	Comment	▼ Static											Record	DInt	0.0	0	False	True	True	True	False			Name	String	4.0	'MANUAL'	False	True	True	True	False			id	DWord	260.0	1	False	True	True	True	False			header	String	264.0	'Temperatur'	False	True	True	True	False			▼ Data											Temperatur	Real	520.0	0.0	False	True	True	True	False		
Name	Data type	Offset	Start value	Retain	Access-ible from HMI/O PC UA/Web API	Wri-ta-ble in engi-neer-ing	Visi-ble in HMI	Set-point	Su-per-vi-sion	Comment																																																																																			
▼ Static																																																																																													
Record	DInt	0.0	0	False	True	True	True	False																																																																																					
Name	String	4.0	'MANUAL'	False	True	True	True	False																																																																																					
id	DWord	260.0	1	False	True	True	True	False																																																																																					
header	String	264.0	'Temperatur'	False	True	True	True	False																																																																																					
▼ Data																																																																																													
Temperatur	Real	520.0	0.0	False	True	True	True	False																																																																																					

Totally Integrated Automation Portal									
Program blocks / System blocks / Program resources									
PID_Compact [FB1130]									
PID_Compact Properties									
General									
Name	PID_Compact	Number	1130	Type	FB				
Language	SCL	Numbering	Automatic						
Information									
Title	Compact PID_Controller with self-tuning	Author	SIMATIC	Comment					
Family	COMPPID	Version	2.3	User-defined ID	PID_Cmpt				
Name	Data type	Default value	Retain	Accessible from HMI/OPC UA/Web API	Writable from engineering HMI/OPC UA/Web API	Visible in HMI engineering	Setpoint	Supervision	Comment
▼ Input									
Setpoint	Real	0.0	Non-retain	True	True	True	False		controller setpoint input
Input	Real	0.0	Non-retain	True	True	True	False		current value from process in REAL format
Input_PER	Int	0	Non-retain	True	True	True	False		current value from peripheral input
Disturbance	Real	0.0	Non-retain	True	True	True	False		disturbance intrusion
ManualEnable	Bool	false	Non-retain	True	True	True	False		activate manual value to overwrite output value
ManualValue	Real	0.0	Non-retain	True	True	True	False		manual value
ErrorAck	Bool	false	Non-retain	True	True	True	False		reset error message
Reset	Bool	false	Non-retain	True	True	True	False		reset the controller
ModeActivate	Bool	false	Non-retain	True	True	True	False		enable mode
▼ Output									
ScaledInput	Real	0.0	Non-retain	True	False	True	False		current value after scaling
Output	Real	0.0	Non-retain	True	False	True	False		output value in REAL format
Output_PER	Int	0	Non-retain	True	False	True	False		analog output value
Output_PWM	Bool	false	Non-retain	True	False	True	False		pulse width modulated output value
SetpointLimit_H	Bool	false	Non-retain	True	False	True	False		setpoint reached upper limit
SetpointLimit_L	Bool	false	Non-retain	True	False	True	False		setpoint reached lower limit

Totally Integrated Automation Portal										
Name	Data type	Default value	Retain	Accessible from HMI/OPC UA/Web API	Writable from HMI/OPC UA/Web API	Visible in engineering	Setpoint	Supervision	Comment	
InputWarning_H	Bool	false	Non-retain	True	False	True	False		current value reached upper warning level	
InputWarning_L	Bool	false	Non-retain	True	False	True	False		current value reached lower warning level	
State	Int	0	Non-retain	True	False	True	False		current mode of operation (0-Inactive, 1-SUT, 2-TIR, 3-Automatic, 4-Manual, 5-Substitute output)	
Error	Bool	false	Non-retain	True	False	True	False		error flag	
ErrorBits	DWord	16#0	Retain	True	False	True	False		error message	
▼ InOut										
Mode	Int	4	Retain	True	True	True	False		mode selection	
▼ Static										
InternalDiagnostic	DWord	0	Non-retain	False	False	False	False		internal diagnostic and version handling	
InternalVersion	DWord	DW#16#02030003	Non-retain	True	False	True	False		version of controller	
InternalRTVersion	DWord	0	Non-retain	False	False	False	False		version of runtime	
IntegralReset-Mode	Int	4	Non-retain	True	True	True	True		0 smooth, 1 clear, 2 keep, 3 overwrite initial output, 4 like setpoint change	
OverwriteInitialOutputValue	Real	0.0	Non-retain	True	True	True	False		initialisation of output value for override control	
RunModeByStart-up	Bool	true	Non-retain	True	True	True	True		activate Mode after CPU restart	
LoadBackUp	Bool	false	Non-retain	True	True	True	False		restore last parameter set	
SetSubstituteOutput	Bool	true	Non-retain	True	True	True	True		assignment of output value in State = 5 (FALSE - last valid value, TRUE - SubstituteOutput)	
PhysicalUnit	Int	0	Non-retain	True	False	True	True		unit of measurement of the process value and setpoint	

Totally Integrated Automation Portal										
Name	Data type	Default value	Retain	Accessible from HMI/OPC UA/Web API	Writable from HMI/OPC UA/Web API	Visible in HMI engineering	Setpoint	Supervision	Comment	
PhysicalQuantity	Int	0	Non-retain	True	False	True	True		physical quantity of the process value and setpoint	
ActivateRecover-Mode	Bool	true	Non-retain	True	True	True	True		FALSE - go to inactive by error, TRUE - activate error treatment	
Warning	DWord	16#0	Retain	True	False	True	False		warning message	
WarningInternal	DWord	16#0	Retain	True	False	True	False		warning message	
Progress	Real	0.0	Non-retain	True	False	True	False		progress of current phase in percent	
CurrentSetpoint	Real	0.0	Non-retain	True	False	True	False		current active setpoint value	
CancelTuningLevel	Real	10.0	Non-retain	True	True	True	True		cancel level for setpoint change during tuning	
SubstituteOutput	Real	0.0	Non-retain	True	True	True	True		substitute output value in case of error	
▼ Config	PID_CompactConfig		Non-retain	True	True	True	True		configuration data set	
InputPerOn	Bool	true	Non-retain	True	True	True	True		activate peripheral input	
InvertControl	Bool	false	Non-retain	True	True	True	True		invert control direction	
InputUpperLimit	Real	120.0	Non-retain	True	True	True	True		input (process value) upper limit	
InputLowerLimit	Real	0.0	Non-retain	True	True	True	True		input (process value) lower limit	
InputUpperWarning	Real	3.402822e+38	Non-retain	True	True	True	True		input (process value) upper level warning	
InputLowerWarning	Real	-3.402822e+38	Non-retain	True	True	True	True		input (process value) lower level warning	
OutputUpperLimit	Real	100.0	Non-retain	True	True	True	True		output value upper limit	
OutputLowerLimit	Real	0.0	Non-retain	True	True	True	True		output value lower limit	
SetpointUpperLimit	Real	3.402822e+38	Non-retain	True	True	True	True		setpoint upper limit value	
SetpointLowerLimit	Real	-3.402822e+38	Non-retain	True	True	True	True		setpoint lower limit value	
MinimumOn-Time	Real	0.0	Non-retain	True	True	True	True		PWM minimum on time	
MinimumOff-Time	Real	0.0	Non-retain	True	True	True	True		PWM minimum off time	

Totally Integrated Automation Portal										
Name	Data type	Default value	Retain	Accessible from HMI/OPC UA/Web API	Writable from HMI/OPC UA/Web API	Visible in engineering	Setpoint	Supervision	Comment	
▼ InputScaling	PID_Scaling		Non-retain	True	True	True	True		input scaling	
UpperPointIn	Real	27648.0	Non-retain	True	True	True	True		high value (input range of scaling)	
LowerPointIn	Real	0.0	Non-retain	True	True	True	True		low value (input range of scaling)	
UpperPointOut	Real	100.0	Non-retain	True	True	True	True		high value (output range of scaling)	
LowerPointOut	Real	0.0	Non-retain	True	True	True	True		low value (output range of scaling)	
▼ CycleTime	PID_CycleTime		Non-retain	True	True	True	True		data set for cycle time estimation	
StartEstimation	Bool	true	Non-retain	True	True	True	False		start automatic estimation of call cycle time	
EnEstimation	Bool	true	Non-retain	True	True	True	True		enable estimation of call cycle time	
EnMonitoring	Bool	true	Non-retain	True	True	True	True		enable monitoring of call cycle time	
Value	Real	0.1	Non-retain	True	True	True	True		call cycle time	
▼ CtrlParamsBackup	PID_CompactControlParams		Non-retain	True	True	True	True		saved parameter set	
Gain	Real	1.0	Non-retain	True	True	True	True		proportional gain	
Ti	Real	20.0	Non-retain	True	True	True	True		reset time	
Td	Real	0.0	Non-retain	True	True	True	True		derivative time	
TdFiltRatio	Real	0.2	Non-retain	True	True	True	True		filter coefficient for derivative part	
PWeighting	Real	1.0	Non-retain	True	True	True	True		weighting of proportional part in direct, feedback path	
DWeighting	Real	1.0	Non-retain	True	True	True	True		weighting of derivative part in direct, feedback path	
Cycle	Real	1.0	Non-retain	True	True	True	True		PID Controller cycle time	
▼ PIDSelfTune	PID_CompactSelfTune		Non-retain	True	True	True	True		data set for self tuning	
▼ SUT	PID_Compact_SUT		Non-retain	True	True	True	True		data set for start up tuning	
CalculateParams	Bool	false	Non-retain	True	True	True	False		recalculate control parameters with parameters of startup tuning	

Totally Integrated Automation Portal									
Name	Data type	Default value	Retain	Accessible from HMI/OPC UA/Web API	Writable from HMI/OPC UA/Web API	Visible in engineering	Setpoint	Supervision	Comment
TuneRule	Int	0	Non-retain	True	True	True	True		tuning rule for SUT (0-CHR PID, 1-CHR PI)
State	Int	0	Non-retain	True	False	True	False		current phase of start up tuning
▼ TIR	PID_Compact_TIR		Non-retain	True	True	True	True		data set for tuning in run
RunIn	Bool	false	Non-retain	True	True	True	False		activate run in setpoint without controlling
CalculateParams	Bool	false	Non-retain	True	True	True	False		recalculate control parameters with parameters of tuning in run
TuneRule	Int	0	Non-retain	True	True	True	True		tuning rule for TIR (0-2-A PID auto, fast, slow; 3-ZN PID; 4-ZN PI; 5-ZN P)
State	Int	0	Non-retain	True	False	True	False		current phase of tuning in run
▼ PIDCtrl	PID_CompactControl		Non-retain	True	True	True	True		data for controlling part
PIDInit	Bool	false	Non-retain	True	True	True	False		initialization of controller
IntegralSum	Real	0.0	Non-retain	True	True	True	False		signal of integral part
▼ Retain	PID_CompactRetain		Retain	True	True	True	True		retain data
▼ CtrlParams	PID_CompactControlParams		Retain	True	True	True	True		actual parameter set
Gain	Real	1.0	Retain	True	True	True	True		proportional gain
Ti	Real	20.0	Retain	True	True	True	True		reset time
Td	Real	0.0	Retain	True	True	True	True		derivative time
TdFiltRatio	Real	0.2	Retain	True	True	True	True		filter coefficient for derivative part
PWeighting	Real	1.0	Retain	True	True	True	True		weighting of proportional part in direct, feedback path
DWeighting	Real	1.0	Retain	True	True	True	True		weighting of derivative part in direct, feedback path
Cycle	Real	1.0	Retain	True	True	True	True		PID Controller cycle time

Totally Integrated Automation Portal									
Program blocks / System blocks / Program resources									
DataLogWrite_DB [DB5]									
DataLogWrite_DB Properties									
General									
Name	DataLogWrite_DB	Number	5	Type	DB				
Language	DB	Numbering	Automatic						
Information									
Title		Author	SIMATIC	Comment					
Family	DataLog	Version	1.0	User-defined ID	DL_Write				
Name	Data type	Start value	Retain	Access-ible from HMI/O PC UA/Web API	Wri-table in HMI engi-neer-ing	Visible in HMI	Set-point	Su-per-vi-sion	Comment
▼ Input									
REQ	Bool	false	False	True	True	True	False		
▼ Output									
DONE	Bool	false	False	True	True	True	False		
BUSY	Bool	false	False	True	True	True	False		
ERROR	Bool	false	False	True	True	True	False		
STATUS	Word	0	False	True	True	True	False		
▼ InOut									
ID	DWord	0	False	True	True	True	False		
Static									

Totally Integrated Automation Portal									
Program blocks / System blocks / Program resources									
IEC_Timer_0_DB [DB6]									
IEC_Timer_0_DB Properties									
General									
Name	IEC_Timer_0_DB	Number	6	Type	DB				
Language	DB	Numbering	Automatic						
Information									
Title		Author	Simatic	Comment					
Family	IEC	Version	1.0	User-defined ID	IEC_TMR				
Name	Data type	Start value	Retain	Access-ible from HMI/O PC UA/Web API	Wri-ta-ble in engi-neer-ing	Visible in HMI	Set-point	Su-per-vi-sion	Comment
▼ Static									
PT	Time	T#0ms	False	True	True	True	False		
ET	Time	T#0ms	False	True	False	True	False		
IN	Bool	false	False	True	True	True	False		
Q	Bool	false	False	True	False	True	False		

Totally Integrated Automation Portal									
Program blocks / System blocks / Program resources									
5sec [DB7]									
5sec Properties									
General									
Name	5sec	Number	7	Type	DB				
Language	DB	Numbering	Automatic						
Information									
Title		Author	Simatic	Comment					
Family	IEC	Version	1.0	User-defined ID	CNTR				
Name	Data type	Start value	Retain	Access-ible from HMI/O PC UA/Web API	Wri-ta-ble in engi-neer-ing	Visible in HMI	Set-point	Su-per-vi-sion	Comment
▼ Static									
CU	Bool	false	True	True	True	True	False		
CD	Bool	false	True	True	True	True	False		
R	Bool	false	True	True	True	True	False		
LD	Bool	false	True	True	True	True	False		
QU	Bool	false	True	True	True	True	False		
QD	Bool	false	True	True	True	True	False		
PV	Int	0	True	True	True	True	False		
CV	Int	0	True	True	True	True	False		

Totally Integrated Automation Portal									
Program blocks / System blocks / Program resources									
10sec [DB8]									
10sec Properties									
General									
Name	10sec	Number	8	Type	DB				
Language	DB	Numbering	Automatic						
Information									
Title		Author	Simatic	Comment					
Family	IEC	Version	1.0	User-defined ID	CNTR				
Name	Data type	Start value	Retain	Access-ible from HMI/O PC UA/Web API	Wri-ta-ble in engi-neer-ing	Visible in HMI	Set-point	Su-per-vi-sion	Comment
▼ Static									
CU	Bool	false	True	True	True	True	False		
CD	Bool	false	True	True	True	True	False		
R	Bool	false	True	True	True	True	False		
LD	Bool	false	True	True	True	True	False		
QU	Bool	false	True	True	True	True	False		
QD	Bool	false	True	True	True	True	False		
PV	Int	0	True	True	True	True	False		
CV	Int	0	True	True	True	True	False		

Totally Integrated Automation Portal									
Program blocks / System blocks / Program resources									
1min [DB9]									
1min Properties									
General									
Name	1min	Number	9	Type	DB				
Language	DB	Numbering	Automatic						
Information									
Title		Author	Simatic	Comment					
Family	IEC	Version	1.0	User-defined ID	CNTR				
Name	Data type	Start value	Retain	Access-ible from HMI/O PC UA/Web API	Wri-table in engineering	Visible in HMI	Set-point	Su-per-vision	Comment
▼ Static									
CU	Bool	false	True	True	True	True	False		
CD	Bool	false	True	True	True	True	False		
R	Bool	false	True	True	True	True	False		
LD	Bool	false	True	True	True	True	False		
QU	Bool	false	True	True	True	True	False		
QD	Bool	false	True	True	True	True	False		
PV	Int	0	True	True	True	True	False		
CV	Int	0	True	True	True	True	False		

Totally Integrated Automation Portal									
Program blocks / System blocks / Program resources									
5min [DB10]									
5min Properties									
General									
Name	5min	Number	10	Type	DB				
Language	DB	Numbering	Automatic						
Information									
Title		Author	Simatic	Comment					
Family	IEC	Version	1.0	User-defined ID	CNTR				
Name	Data type	Start value	Retain	Access-ible from HMI/O PC UA/Web API	Wri-table in engineering	Visible in HMI	Set-point	Su-per-vision	Comment
▼ Static									
CU	Bool	false	True	True	True	True	False		
CD	Bool	false	True	True	True	True	False		
R	Bool	false	True	True	True	True	False		
LD	Bool	false	True	True	True	True	False		
QU	Bool	false	True	True	True	True	False		
QD	Bool	false	True	True	True	True	False		
PV	Int	0	True	True	True	True	False		
CV	Int	0	True	True	True	True	False		

Totally Integrated Automation Portal									
Program blocks / System blocks / Program resources									
10min [DB11]									
10min Properties									
General									
Name	10min	Number	11	Type	DB				
Language	DB	Numbering	Automatic						
Information									
Title		Author	Simatic	Comment					
Family	IEC	Version	1.0	User-defined ID	CNTR				
Name	Data type	Start value	Retain	Access-ible from HMI/O PC UA/Web API	Wri-ta-ble in engi-neer-ing	Visible in HMI	Set-point	Su-per-vi-sion	Comment
▼ Static									
CU	Bool	false	True	True	True	True	False		
CD	Bool	false	True	True	True	True	False		
R	Bool	false	True	True	True	True	False		
LD	Bool	false	True	True	True	True	False		
QU	Bool	false	True	True	True	True	False		
QD	Bool	false	True	True	True	True	False		
PV	Int	0	True	True	True	True	False		
CV	Int	0	True	True	True	True	False		

Totally Integrated Automation Portal									
Program blocks / System blocks / Program resources									
TIME_Seconds [DB12]									
TIME_Seconds Properties									
General									
Name	TIME_Seconds	Number	12	Type	DB				
Language	DB	Numbering	Automatic						
Information									
Title		Author	Simatic	Comment					
Family	IEC	Version	1.0	User-defined ID	CNTR				
Name	Data type	Start value	Retain	Access-ible from HMI/O PC UA/Web API	Wri-ta-ble in engi-neer-ing	Visible in HMI	Set-point	Su-per-vi-sion	Comment
▼ Static									
CU	Bool	false	True	True	True	True	False		
CD	Bool	false	True	True	True	True	False		
R	Bool	false	True	True	True	True	False		
LD	Bool	false	True	True	True	True	False		
QU	Bool	false	True	True	True	True	False		
QD	Bool	false	True	True	True	True	False		
PV	Int	0	True	True	True	True	False		
CV	Int	0	True	True	True	True	False		

Totally Integrated Automation Portal									
Program blocks / System blocks / Program resources									
TIME_Minutes [DB14]									
TIME_Minutes Properties									
General									
Name	TIME_Minutes	Number	14	Type	DB				
Language	DB	Numbering	Automatic						
Information									
Title		Author	Simatic	Comment					
Family	IEC	Version	1.0	User-defined ID	CNTR				
Name	Data type	Start value	Retain	Access-ible from HMI/O PC UA/Web API	Wri-table in engineering	Visible in HMI	Set-point	Su-per-vision	Comment
▼ Static									
CU	Bool	false	True	True	True	True	False		
CD	Bool	false	True	True	True	True	False		
R	Bool	false	True	True	True	True	False		
LD	Bool	false	True	True	True	True	False		
QU	Bool	false	True	True	True	True	False		
QD	Bool	false	True	True	True	True	False		
PV	Int	0	True	True	True	True	False		
CV	Int	0	True	True	True	True	False		

Totally Integrated Automation Portal									
Program blocks / System blocks / Program resources									
TIME_Hours [DB15]									
TIME_Hours Properties									
General									
Name	TIME_Hours	Number	15	Type	DB				
Language	DB	Numbering	Automatic						
Information									
Title		Author	Simatic	Comment					
Family	IEC	Version	1.0	User-defined ID	CNTR				
Name	Data type	Start value	Retain	Accessible from HMI/O PC UA/Web API	Writable from engineering	Visible in HMI	Set-point	Supervision	Comment
▼ Static									
CU	Bool	false	True	True	True	True	False		
CD	Bool	false	True	True	True	True	False		
R	Bool	false	True	True	True	True	False		
LD	Bool	false	True	True	True	True	False		
QU	Bool	false	True	True	True	True	False		
QD	Bool	false	True	True	True	True	False		
PV	Int	0	True	True	True	True	False		
CV	Int	0	True	True	True	True	False		

Totally Integrated Automation Portal									
Program blocks / System blocks / Program resources									
DataLogWrite_DB_1 [DB19]									
DataLogWrite_DB_1 Properties									
General									
Name	DataLogWrite_DB_1	Number	19	Type	DB				
Language	DB	Numbering	Automatic						
Information									
Title		Author	SIMATIC	Comment					
Family	DataLog	Version	1.0	User-defined ID	DL_Write				
Name	Data type	Start value	Retain	Access-ible from HMI/O PC UA/Web API	Wri-table in engi-neer-ing	Visible in HMI	Set-point	Su-per-vi-sion	Comment
▼ Input									
REQ	Bool	false	False	True	True	True	False		
▼ Output									
DONE	Bool	false	False	True	True	True	False		
BUSY	Bool	false	False	True	True	True	False		
ERROR	Bool	false	False	True	True	True	False		
STATUS	Word	0	False	True	True	True	False		
▼ InOut									
ID	DWord	0	False	True	True	True	False		
Static									

Totally Integrated Automation Portal											
Name	Data type	Offset	Start value	Retain	Access-ible from HMI/PC UA/ Web API	Wri-ta-ble in HMI engi-neer-ing PC UA/ Web API	Visi-ble in HMI engi-neer-ing	Set-point	Su-per-vision	Comment	
enumref-tab_count	UInt	38.0	0	False	False	False	False	False			
enumtab_of	UInt	40.0	98	False	False	False	False	False			
enumtab_count	UInt	42.0	0	False	False	False	False	False			
textlist_of	UInt	44.0	98	False	False	False	False	False			
textlist_count	UInt	46.0	12	False	False	False	False	False			
lan-guage_frag_tab_of	UInt	48.0	92	False	False	False	False	False			
lan-guage_frag_tab_count	UInt	50.0	6	False	False	False	False	False			
applica-tion_name	UInt	52.0	1	False	False	False	False	False			
application_url	UInt	54.0	2	False	False	False	False	False			
application_desc	UInt	56.0	12	False	False	False	False	False			
enum_defs_frag-ment_start	UInt	58.0	0	False	False	False	False	False			
enum_defs_frag-ment_count	UInt	60.0	0	False	False	False	False	False			
▼ commandstate	Struct	62.0		False	False	False	False	False			
last_error	Int	62.0	0	False	False	False	False	False			
debug_mode	Int	64.0	0	False	False	False	False	False			
init	Bool	66.0	True	False	False	False	False	False			
deactivate	Bool	66.1	False	False	False	False	False	False			
initializing	Bool	66.2	False	False	False	False	False	False			
error	Bool	66.3	False	False	False	False	False	False			
deactivating	Bool	66.4	False	False	False	False	False	False			
deactivated	Bool	66.5	False	False	False	False	False	False			
initialized	Bool	66.6	False	False	False	False	False	False			
reserved1	Bool	66.7	False	False	False	False	False	False			
reserved2	Byte	67.0	B#16#00	False	False	False	False	False			

Totally Integrated Automation Portal											
Name	Data type	Offset	Start value	Retain	Access-ible from HMI/OPC UA/ Web API	Wri-ta-ble in HMI engi-neer-ing	Visi-ble in HMI engi-neer-ing	Set-point	Su-per-vision	Comment	
aborting	Bool	78.7	False	False	False	False	False	False			
reserved3	Byte	79.0	B#16#00	False	False	False	False	False			
▼ requesttab[3]	Struct	80.0		False	False	False	False	False			
page_index	UInt	80.0	0	False	False	False	False	False			
frag-ment_in-dex	UInt	82.0	0	False	False	False	False	False			
continue	Bool	84.0	False	False	False	False	False	False			
repeat	Bool	84.1	False	False	False	False	False	False			
abort	Bool	84.2	False	False	False	False	False	False			
finish	Bool	84.3	False	False	False	False	False	False			
idle	Bool	84.4	False	False	False	False	False	False			
waiting	Bool	84.5	False	False	False	False	False	False			
sending	Bool	84.6	False	False	False	False	False	False			
aborting	Bool	84.7	False	False	False	False	False	False			
reserved3	Byte	85.0	B#16#00	False	False	False	False	False			
▼ requesttab[4]	Struct	86.0		False	False	False	False	False			
page_index	UInt	86.0	0	False	False	False	False	False			
frag-ment_in-dex	UInt	88.0	0	False	False	False	False	False			
continue	Bool	90.0	False	False	False	False	False	False			
repeat	Bool	90.1	False	False	False	False	False	False			
abort	Bool	90.2	False	False	False	False	False	False			
finish	Bool	90.3	False	False	False	False	False	False			
idle	Bool	90.4	False	False	False	False	False	False			
waiting	Bool	90.5	False	False	False	False	False	False			
sending	Bool	90.6	False	False	False	False	False	False			

